

BEA ARCHITECTURAL SPECIFICATION SHEET Sliding Door Solutions: IXIO-DT1

Product Specifications

Activation and Safety Sensor for Sliding/Telescopic Doors providing motion detection activation and presence detection safety, along the door opening, via microwave (motion detection) K-band (24.125GHz) and active infrared technologies.

- 1. Mounting Range Capabilities:
 - a. Mounting Height Standard: 78 in. to 138 in. (198.12 cm to 350.52 cm)
- 2. Thermal Range Requirements: Provide sensor that can be used in all climates, allow for thermal range from minus 14° F to 131° F (-10° C to 55° C)
- 3. Activation portion of the sensor shall detect a 28 inch (71.12 cm) minimum high person, moving at a rate of 2.2 (5.6 cm) inches per second minimum toward the center of the door, within the detection areas described per ANSI 156.10
 - a. The sensor shall provide a maximum field of motion detection of 156 in. wide up to 98 in. deep. (396.24 cm x 248.92 cm)
 - Microwave activation portion of the sensor shall have bi-directional, unidirectional or motion tracking sensing capabilities and utilize a flat planar antenna.
 - c. Provide a means to adjust the activation zone vertical angle from 0 degrees to 45 degrees as measured from the face of the door
 - d. Infrared curtains shall have angle adjustment capability from -7 ° to 4 ° and shall be capable of reaching within 2 inches (5.1 cm) of the face of the sliding door.
 - e. The infrared curtains shall not shut off at any door position.
 - f. The presence detection shall consist of two (2) curtains with a total of 48 infrared spots and shall be used for the purpose of pedestrian detection, along the door opening, on both sides of the door.
 - g. Infrared portion of the sensor shall be able to detect a motionless 28" (71.1cm) High x 12" (30.5cm) Wide x 8" (20.3cm) Deep test object for a minimum of 30 seconds.
 - h. Presence (Infrared pattern): The infrared field shall be adjusted via a shutter and provide at least 4 different patters widths with a minimum of 42 in (106.68 cm) when mounted at 86 in. (218.44 cm) and a maximum width of 138 in. (350.52 cm) when mounted at 138 in. (350.52 cm).
 - i. Infrared Automatic Learn time: Factory setting for "learn mode" to be compliant per ANSI 156.10 minimum learn time of 30 seconds. Auto learn modes shall be adjustable to infinity.
- 4. Sensor shall provide visible spots to verify placement of infrared field.

BEA Inc.RIDC Park West
100 Enterprise Drive
Pittsburgh, PA 15275-1213

Phone: 1.800.523.2462 Fax: 1.888.523.2462









- 5. Sensor shall be fully adjustable by remote control and/or LCD display and provide a means to prevent unauthorized adjustments.
- 6. Sensor shall have internal monitoring for fault conditions and provide for a means of external monitoring by door control.
- 7. Product shall be installed by a technician who is AAADM certified

Product image and Application Photo







Technical Specs:

Technology	Microwave Doppler Radar	Infrared
Detection mode	Motion	Presence
Transmitter Frequency	24.150 GHz	N/A
Transmitter Radiated Power	< 20 dBmEIRP	N/A
Transmitter Power Density	< 5 mW/cm ²	N/A
Spot Size	N/A	2 in × 2 in (5.1 cm x 5.1 cm)
Max. Number of Spots	N/A	24 per curtain
Max. Number of Curtains	N/A	2
Supply Voltage	12 to 24 VAC 50/60 Hz 12 to 35 VDC	
Output	Solid-state-relay (potential and polarity free)	

_	
Max. Contact Current	400 mA
Max. Contact Voltage	42 VDC
Adjustable hold time	Microwave: 0.5 to 9 sec.
Power Consumption	< 2.5 W
Mounting Height	78 in. – 138 in. (198.2 cm to 350.52 cm)
Temperature Range	Sensor: -31°F to +131°F (-35°C to 55°C) LCD: 14°F to +131°F (-10°C to 55°C) 0 to 95% relative humidity, non condensing
Protection Degree	IP54
Norm Conformity	R&TTE 1999/5/EC; EMC 2004/108/EC; MD 2006/42/EC; RoHS 2002/95/EC
Cable Length	120 in (304.8 cm)

Dimensions:

BEA Inc. RIDC Park West 100 Enterprise Drive Pittsburgh, PA 15275-1213


Phone: 1.800.523.2462 Fax: 1.888.523.2462








10.6" W x 2.25"D X 2.28"H





BEA Inc. RIDC Park West 100 Enterprise Drive Pittsburgh, PA 15275-1213

Phone: 1.800.523.2462 Fax: 1.888.523.2462



