


Input 1 and Input 2 are activation inputs for Door 1 and Door 2 respectively

Inputs 3 and 4 are for the DPSs for door 1 (input 3) and door 2 (input 4) respectively. Switch is closed when door is closed.

SEE NOTE 1



SEE NOTE 2



SEE NOTE 4



SEE NOTE 3 & 5



SEE NOTE 3 & 5

DPS = Door position switch

NOTES:

1. PUSH PLATES ARE DRY CONTACT NORMALLY OPEN SWITCHES
2. DOOR POSITION SWITCHES ARE NORMALLY CLOSED SWITCH IS CLOSED WHEN DOOR IS CLOSED.
3. MAGLOCK AUXILIARY RELAY CONTACTS WILL BE OPEN WHEN LOCK IS POWERED AND BONDED.
4. SET OUTPUT OPTION ON Br-3 TO DRY. REMOVE POWER BEFORE CHANGING.
5. MAGLOCKS ARE NON-UL RATED. IF USING UL RATED MAGLOCKS A UL RATED POWER SUPPLY IS REQUIRED. P/N10PS1224

IF AFTER TROUBLESHOOTING A PROBLEM, A SATISFACTORY SOLUTION CANNOT BE ACHIEVED, PLEASE CALL B.E.A., INC. FOR FURTHER ASSISTANCE DURING EASTERN STANDARD TIME AT 1-800-523-2462 FROM 8AM - 5PM. FOR AFTER-HOURS, CALL EAST COAST: 1-866-249-7937 OR 1-866-836-1863/ MID-WEST: 1-800-407-4545 OR 1-888-308-8843 / WEST COAST: 1-888-419-2564. DO NOT LEAVE ANY PROBLEM UNRESOLVED. IF YOU MUST WAIT FOR THE FOLLOWING WORKDAY TO CALL B.E.A., LEAVE THE DOOR INOPERABLE UNTIL SATISFACTORY REPAIRS CAN BE MADE. NEVER SACRIFICE THE SAFE OPERATION OF THE AUTOMATIC DOOR OR GATE FOR AN INCOMPLETE SOLUTION. WEB: WWW.BEASENSORS.COM

		100 ENTERPRISE DRIVE PITTSBURGH, PA 15275 PHONE: (412) 249-4100 FAX: (412) 249-4101 EMAIL: www.beasensors.com	
<b>TITLE: Br-3 TWO MANUAL DOORS INTERLOCKED W/MAGLOCKS AND BUZZERS</b>			
SIZE:	DRAWN BY: WJR	REV BY: JED	PART NO: 80.0317.00
A	SCALE: NONE	DATE: 2010, March 24	SHEET 1 OF 1