



- NOTES:**
- 1) IS40/IS40P CAN BE REPLACED BY ANY SENSOR WITH A NORMALLY CLOSED OUTPUT WHEN NOT IN DETECTION.
 - 2) PRIOR TO APPLYING POWER SET JUMPERS ON BR3 FOR A "WET / D.C." OUTPUT.
 - 3) SET BR3 TO FUNCTION "10" PER USERS GUIDE. SET H1 TIMER TO DELAY ACTIVATION OF LIGHT.

FUNCTIONALITY: WHEN SENSOR IS NOT IN DETECTION BR3 INPUT 1 WILL BE SHUNTED AND RELAY 1 WILL BE HELD ACTIVE. WHEN SENSOR IS IN DETECTION INPUT 1 WILL NOT BE SHUNTED ALLOWING BR3 TIMER H-1 TO RUN. IF THE SENSOR REMAINS IN DETECTION UNTIL TIMER H-1 EXPIRES LIGHT WILL BE ILLUMINATED. IF SENSOR LOSES DETECTION BEFORE TIMER H-1 EXPIRES INPUT 1 WILL BE SHUNTED AGAIN AND RELAY 1 WILL BE ACTIVE AGAIN.

100 ENTERPRISE DRIVE
 PITTSBURGH, PA 15275
 PHONE: (412) 249-4100
 FAX: (412) 249-4101
 EMAIL: www.beasensors.com

**TITLE: BR3 - MANUAL DOOR
 PROP ALARM**

SIZE: A	DRAWN BY: WJR	REV BY:	PART NO: 80.0356.00
SCALE: NONE	DATE: 06 June, 2013	SHEET 1 OF 1	

